

2021 JUN -7 PM 3:35



MISSISSIPPI STATE DEPARTMENT OF HEALTH

2020 CERTIFICATION

Consumer Confidence Report (CCR)

New Zion Utilities, Inc.

Public Water System Name

0660004

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

CCR DISTRIBUTION (Check all boxes that apply.)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bills (Attach copy of bill)	6/1/2021 - 7/1/2021
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other _____	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input checked="" type="checkbox"/> Distributed via U. S. Postal Mail	6-1-21 / 7-1-21
<input type="checkbox"/> Distributed via E-Mail as a URL (Provide Direct URL): _____	
<input type="checkbox"/> Distributed via E-Mail as an attachment	
<input type="checkbox"/> Distributed via E-Mail as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input type="checkbox"/> Posted in public places (attach list of locations)	
<input checked="" type="checkbox"/> Posted online at the following address (Provide Direct URL): <u>https://msrwa.org/2020CCR/newzionutilities.pdf</u>	

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Vicki Byrd
 Name

Bookkeeper
 Title

6-7-21
 Date
SUBMISSION OPTIONS (Select one method ONLY)

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)

MSDH, Bureau of Public Water Supply

P.O. Box 1700

Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576-7800

(NOT PREFERRED)

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

2020 Annual Drinking Water Quality Report
New Zion Utilities, Inc.
PWS#: 0660004
May 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies.

If you have any questions about this report or concerning your water utility, please contact Mitchell Marshall at 601.716.4650. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at the meeting scheduled for the last Tuesday of each month at 6:00 PM at the New Zion Baptist Church. (At this time meetings are being held by Zoom).

Our water source is from wells drawing from the Miocene Series and Catahoula Formation Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the New Zion Utilities have received a moderate ranking in terms of susceptibility to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination

Inorganic Contaminants								
10. Barium	N	2019*	.0074	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019*	.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018/20	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019*	.233	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2020	4	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2020	3.88	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	1.3	.8 – 1.7	mg/l	0	MRDL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2020.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The New Zion Utilities works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Please note: This CCR will not be mailed/delivered to each customer.

NEW ZION UTILITIES
3153 Highway 49
PO BOX 816
WIGGINS, MS 39577
601-928-5727

This institution is an equal opportunity provider and employer

WATER USED 4382	Previous Balance:	0.00
PRES 61698		26.91
MS SALES TAX		1.88

TOTAL NEW CHARGES ON 06/01/21 28.79

YOU OWE 28.79 by 06/15/21
After 06/15/21 pay 31.48

Last Pmt \$33.03 05/11/21 A & D TIMBER
SVC:04/27/21-05/24/21 (27 days) Acct# 0252
457 THELMA ANDREWS RD

****SEE BACK OF BILL FOR IMPORTANT MESSAGE****

FIRST-CLASS MAIL
PRESORTED
US POSTAGE PAID
ZIP CODE 39577
PERMIT # 27

Return this portion with payment

Billed: 06/01/21

YOU OWE 28.79 by 06/15/21
After 06/15/21 pay 31.48

Acct# 0252
457 THELMA ANDREWS RD

A & D TIMBER
P O BOX 550
WIGGINS MS 39577

NEW ZION UTILITIES
3153 Highway 49
PO BOX 816
WIGGINS, MS 39577
601-928-5727

This institution is an equal opportunity provider and employer

WATER USED 5000	Previous Balance:	0.00
PRES 70000		30.00
MS SALES TAX		2.10

TOTAL NEW CHARGES ON 06/01/21 32.10

YOU OWE 32.10 by 06/15/21
After 06/15/21 pay 35.10

Last Pmt \$32.10 05/11/21 A & D TIMBER
SVC:04/27/21-05/24/21 (27 days) Acct# 5600
465 T ANDREWS ROAD

****SEE BACK OF BILL FOR IMPORTANT MESSAGE****

FIRST-CLASS MAIL
PRESORTED
US POSTAGE PAID
ZIP CODE 39577
PERMIT # 27

Return this portion with payment

Billed: 06/01/21

YOU OWE 32.10 by 06/15/21
After 06/15/21 pay 35.10

Acct# 5600
465 T ANDREWS ROAD

A & D TIMBER
P O BOX 550
WIGGINS MS 39577

NEW ZION UTILITIES
3153 Highway 49
PO BOX 816
WIGGINS, MS 39577
601-928-5727

This institution is an equal opportunity provider and employer

WATER USED 4427	Previous Balance:	0.00
PRES 323265		27.14

TOTAL NEW CHARGES ON 06/01/21 27.14

27.14 PAID BY DIRECT DEBIT

Last Pmt \$31.70 05/12/21 KWAYA ADAMS
SVC:04/27/21-05/24/21 (27 days) Acct# 0032
12 REV R POWE RD

****SEE BACK OF BILL FOR IMPORTANT MESSAGE****

FIRST-CLASS MAIL
PRESORTED
US POSTAGE PAID
ZIP CODE 39577
PERMIT # 27

Return this portion with payment

Billed: 06/01/21

27.14 PAID BY DIRECT DEBIT

Acct# 0032
12 REV R POWE RD

KWAYA ADAMS
12 REV R POWE RD
WIGGINS MS 39577

FIRST-CLASS MAIL
PRESORTED
US POSTAGE PAID
ZIP CODE 39577
PERMIT # 27

Return this portion with payment

Billed: 06/01/21

YOU OWE 20.00 by 06/15/21
After 06/15/21 pay 22.00

Acct# 2630
THELMA ANDREWS ROAD

MAMIE ADAMS
3 REV R POWE RD
WIGGINS MS 39577

NEW ZION UTILITIES
3153 Highway 49
PO BOX 816
WIGGINS, MS 39577
601-928-5727

This institution is an equal opportunity provider and employer

WATER USED 2513	Previous Balance:	0.00
PRES 371156		20.00

TOTAL NEW CHARGES ON 06/01/21 20.00

YOU OWE 20.00 by 06/15/21
After 06/15/21 pay 22.00

Last Pmt \$20.00 05/17/21 MAMIE ADAMS
SVC:04/27/21-05/24/21 (27 days) Acct# 2630
THELMA ANDREWS ROAD

****SEE BACK OF BILL FOR IMPORTANT MESSAGE****

*****IMPORTANT NOTICE*****

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER IS
AVAILABLE IN THE 2020 CONSUMER CONFIDENCE REPORT AT:
<https://msrwa.org/2020ccr/newzionutilities.pdf>
YOU MAY REQUEST A HARD COPY BY CHECKING
HERE _____
OR BY CALLING OUR OFFICE AT 601-928-5727

*****IMPORTANT NOTICE*****

*****IMPORTANT NOTICE*****

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER IS
AVAILABLE IN THE 2020 CONSUMER CONFIDENCE REPORT AT:
<https://msrwa.org/2020ccr/newzionutilities.pdf>
YOU MAY REQUEST A HARD COPY BY CHECKING
HERE _____
OR BY CALLING OUR OFFICE AT 601-928-5727

*****IMPORTANT NOTICE*****

*****IMPORTANT NOTICE*****

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER IS
AVAILABLE IN THE 2020 CONSUMER CONFIDENCE REPORT AT:
<https://msrwa.org/2020ccr/newzionutilities.pdf>
YOU MAY REQUEST A HARD COPY BY CHECKING
HERE _____
OR BY CALLING OUR OFFICE AT 601-928-5727

*****IMPORTANT NOTICE*****

*****IMPORTANT NOTICE*****

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER IS
AVAILABLE IN THE 2020 CONSUMER CONFIDENCE REPORT AT:
<https://msrwa.org/2020ccr/newzionutilities.pdf>
YOU MAY REQUEST A HARD COPY BY CHECKING
HERE _____
OR BY CALLING OUR OFFICE AT 601-928-5727

*****IMPORTANT NOTICE*****